



**BUILDING CODE AMENDMENTS
TO THE**

**2015
INTERNATIONAL
RESIDENTIAL
BUILDING
CODE**

RESIDENTIAL BUILDING CODE

When adopting the 2015 International Residential Code, the following Appendices will also be adopted: A, B, C, D, G, J, M & N. Please see last page for Appendices amendments.

AMEND Section R101.1 as follows:

R101.1 Title

These provisions shall be known as the Residential Code for One-and Two-Family Dwellings of The City of Bartlett, and shall be cited as such and will be referred to herein as “this code.”

AMEND Section 103.1 to read as follows:

R103.1 Creation of Enforcement Agency

The Department of Code Enforcement is hereby created and the official in charge thereof shall be known as the Director of Code Enforcement.

DELETE Section R103.2 in its entirety and replace with the following:

R103.2 Code Official Qualifications

The Code Official shall have at least 10 years’ experience or equivalent, as an architect, engineer, inspector, contractor, or superintendent of construction, or any combination of these, five years of which have been in responsible charge of work. The Code Official should be certified as a Building Official through a recognized certification program or have a combination of education and experience acceptable to the governing authority. The Code Official shall be appointed by the Mayor and shall serve at his will and pleasure.

DELETE Section R103.3 in its entirety and replace with the following:

R103.3 Inspector Qualifications

The Code Official, with the approval of the applicable governing authority, may hire such number of officers, inspectors, assistants and other employees as shall be authorized from time to time. A person shall not be hired as inspector of construction who has not had at least five (5) years’ experience as an inspector, engineer, architect, or as a superintendent, foreman, or competent mechanic in charge of construction. The inspector shall be certified through a recognized certification program as an inspector in their area of responsibility within twelve months of his/her date of hire.

ADD New Section 103.4 as follows:

R103.4 Restrictions on Employees

An officer or employee connected with the department, except one whose only connection is as a member of the board established by this code, shall not be financially interested in the furnishing of labor, material, or appliances for the construction, alteration, or maintenance of a building, structure, service, system, or in the making of plans or of specifications thereof, unless he is the owner of such. This officer or employee shall not engage in any other work which is inconsistent with his duties or conflict with the interests of the department.

DELETE R105.1 in its entirety and replace with the following:

R105.1 Permit Application Required

Any owner, authorized agent, or contractor who desires to construct, enlarge, alter, repair, move, demolish, or change the occupancy of a building or structure, or to erect, install, enlarge, alter, repair, remove, convert or replace any electrical, gas, mechanical, or plumbing system or to cause any such work to be done shall first hire or cause to hire a licensed and/or registered contractor. The contractor shall first make application to the Code Official and obtain the required permit for the work. Building permits may be issued to the property and building owners when so allowed by the City of Bartlett Technical Codes and the State of Tennessee Contractors' License Laws. Alterations, repairs or rehabilitation work may be made to any existing structure, building, electrical, gas, mechanical or plumbing system without requiring the building, structure, plumbing, electrical, mechanical or gas system to comply with all the requirements of this code, provided that the alteration, repair or rehabilitation work conforms to the requirements of this code for new construction. The Code Official shall determine the extent to which the existing system shall be made to conform to the requirements of this code for new construction. Permits are required to be obtained by an individual licensed in that field for plumbing, gas, mechanical, and electrical.

ADD a new subsection R105.1.1 entitled "Design and Construction of Retaining Walls" which shall read as follows:

R105.1.1 Design and Construction of Retaining Walls

Retaining wall systems shall be designed by a professional engineer, licensed to practice in the State of Tennessee, for all loads as specified in the Building Code and within this Chapter and in keeping with nationally recognized standards. Design shall be based upon sound engineering and geo-technical principles.

DELETE in R105.2 under Building: 1, 2, 3, 4, 5, 7, 9, & 10.

DELETE in R105.2 under Mechanical: 4 & 7

ADD to the end of Section R105.3.1 as follows:

R105.3.1

When a building or structure is improved and/or remodeled and the value of the work to be completed exceeds 50% of the market value of the building or structure before the damage has occurred, the structure or building shall be improved or remodeled to the requirements for new construction as determined by the Director of Code Enforcement.

DELETE Section R112.3 and replace with the following:

R112.3 Board of Mayor and Aldermen

The Board of Mayor and Aldermen shall be The Code Appeals Board of the City of Bartlett.

RESIDENTIAL BUILDING CODE

Table R301.2 (1) shall read as follows and all existing footnotes shall remain unchanged.

**Table R301.2 (1)
Climatic and Geographic Design Criteria**

Wind Design

Subject to Damage from

Ground Snow Load	Speed (mph) ^d	Topographic Effects ^k	Seismic Design Category ^g	Weathering ^a	Frost Depth Line ^b	Termite ^e	Decay ^d	Winter Design Temp (°F) ^f	Ice Barrier Underlayment Required ⁱ	Flood Hazard ^h	Air Freezing Index ^j	Mean Annual Temp
10 lb/ft ₂	89	No	D1	Moderate	5 inches	Moderate to Heavy	Moderate to Severe	18	No	9/29/2007	158	61.8

ADD Section R301.2.2 as follows:

R301.2.2 Seismic Provisions.

The seismic provisions of this code shall apply as follows:

1. Townhouse in Seismic Design Categories C, D₀, D₁ and D .
2. Detached one and two family dwellings in D₀, D₁ and D , however, such detached one and two family dwellings constructed using wood framing in Seismic Design Categories D₀, D₁ and D shall be allowed, as an alternative compliance method for meeting the structural requirements of this code’s seismic provisions, to comply with the requirement in Section R301.2.2.3.8.

ADD Section R301.2.2.3.5 titled “Full Exterior Wood Structural Sheathing” as follows:

R301.2.2.3.5 Full Exterior Wood Structural Sheathing

One and two family houses shall be constructed with full exterior 7/16 inch (11 mm) minimum wood structural sheathing as a method of compliance with seismic protection requirements. In parts of the structure that do not provide sufficient support from such sheathing, such as certain garage door openings, or when the owner wished to use such devices as a method of meeting seismic requirements engineered braced wall panels are also allowed.

R301.2.2.3.8 Alternative Compliance Method for Structural Requirements

In addition to meeting all the structural requirements for Seismic Design Category C and Sections R301.2.2.3.1, R301.2.2.3.6 and R301.2.2.3.7, an alternative compliance method for meeting structural requirements when wood framing is used shall include compliance with the following items. In the event any requirement in this section differs from wind code structural requirements, the more stringent will apply.

R301.2.2.3.8.1 Anchorage Exterior Walls (Sole Plates)

Exterior wall sole plates shall be secured to the foundation or framing below by one of the following methods:

- 1) **Foundation:** ½ inch (12.7 mm) anchor bolts, with 3 inch by 3 inch (76 mm by 76 mm) washers, embedded in the foundation a minimum of 7 inches (178 mm) in depth. Such anchor bolts are to be placed 4 feet on center maximum and within 12 inches (305 mm) of the end of each plate section. A minimum of 2 anchors per plate section is required.
- 2) **Foundation:** MASA anchors or equivalent embedded in the foundation and placed at 4 feet (1219 mm) on center maximum and within 12 inches (305 mm) of the end of each plate section. A minimum of 2 anchors per plate section is required.
- 3) **Elevated Floors:** 10d nails placed at 8 inches on center and embedded in a continuous rim board. Rim board depth to match depth of floor framing. Rim board shall be nailed to the end of each floor framing member with three 10d nails. Where floor framing parallels exterior wall, 2 rim boards shall be provided and nailed per Table R602.3(1). The Rim board shall be fastened to wall top plate with metal plates at 6 feet (1829 mm) on center; installed plate capacity shall equal or exceed 440 pounds.

R301.2.2.3.8.2 Anchorage All Structural Interior Walls (Sole Plates)

Interior wall framing shall be secured by one of the following methods:

- 1) **Foundation:** ½ inch (12.7 mm) anchor bolts, with 3 inch by 3 inch (76 mm by 76 mm) washers, embedded a minimum of 7 inches (178 mm) in depth in the concrete foundation (thickened slab) at 4 feet (1219 mm) on center maximum and within 12 inches (305 mm) of the end of each plate section.
- 2) **Foundation:** By power actuated fasteners that provide 210 pounds per linear foot shear capacity, placed 2 feet (610 mm) on center maximum and within 12 inches (305 mm) of each plate section or equivalent means of anchorage. A minimum of 2 anchors are required per plate section.
- 3) **Elevated Floors:** 10d nails placed at 8 inches (204 mm) on center and embedded in one of the following:
 - a) Structural wall top plate flush with bottom of floor sheathing, or
 - b) Floor joist parallel with and directly below plate, or
 - c) Blocking, depth to match, placed between floor joists and running the full length of the plate. Blocking to be nailed per Table R602.3(1).

R301.2.2.3.8.3 Stud Spacing – Exterior Walls

All 2x4 exterior walls shall be a maximum of 16 inch (406 mm) stud spacing up to 3 stories. Gypcrete flooring or similar cementitious leveling products shall not be used on elevated floors.

EXCEPTION: Thin-set or other base material required for installation of flooring products in isolated confined spaces such as bathrooms.

R301.2.2.3.8.4 Wall Sheathing

R301.2.2.3.8.4.1 Exterior Wall Sheathing

Exterior wall sheathing shall be 7/16 inch (11 mm) exterior rated OSB or equivalent or 7/16 inch (11 mm) plywood minimum. Sheathing is to be fastened every 6 inches (156 mm) on the edges and 12 inches (305 mm) at intermediate supports.

R301.2.2.3.8.4.2 Interior Structural Wall Sheathing

Interior sheathing shall be a minimum of ½ inch (12.7 mm) gypsum fastened every 7 inches (178 mm) at intermediate supports.

R301.2.2.3.8.5 Garage Door Openings

Brace wall panels are required for garage openings as per Section R602.10.6 of this code.

Exception: An engineered pre-manufactured wall panel is allowed to be used at garage openings.

R301.2.2.3.8.6 APA Narrow Wall Systems Are Not Permitted

Use of APA narrow wall systems is not permitted for establishing compliance with these requirements.

R301.2.2.3.8.7 Connections Across Floor Joist Space

18 gauge galvanized steel coil strapping (ex. CS 18) installed at 48 inch (1219 mm) on center across floor joist space or equivalent is required on all exterior walls and stacked interior structural walls. Strapping shall run vertical along edge of studs and shall be centered on floor joist space. Studs shall be vertically aligned.

R301.2.2.3.8.8 Roof Framing Connections

Roof framing members shall be fastened to wall top plate with 18 gauge galvanized steel clips (ex. H2.5A) or equivalent, not to exceed 48 inches (1219 mm) on center maximum. Provide clips in addition to fastening requirements in Table R602.3(1). This requirement applies to all contact points with load bearing walls. In the event wind fastening requirements differ, the more stringent shall apply.

R301.2.2.3.8.9 Shearwall Holddowns

- 1) Exterior walls: A single holddown shall be installed at each end of each wall over 8 feet (2438 mm) in length (2 holddowns per wall length). Holddown capacity (P), in pounds, shall equal to 210 lbs/ft times wall height ($P=210*H$).
- 2) Wall height (H): distance from wall bottom plate to wall top plate.
- 3) A cut sheet of the hold down type(s) used shall be provided to Code Enforcement when requested by the Building Official. Cut sheet shall show tested product load rating and manufacturer information.

R301.2.2.3.8.10 Opening straps/clips

This section applies only to window and door openings and only to openings located in exterior walls and interior structural walls. Louver, pipe penetrations, dryer vents, and all other wall openings are not required to meet this section unless they exceed 4 sq. ft. in area.

- 1) **Studs above and below headers and window sill plates:** Provide 18 gauge galvanized steel clips (ex. H2.5A) or equivalent at 32 inches (813 mm), top and bottom of studs, minimum 2 clips per opening width at headers and sills.
- 2) **Headers:** Headers shall bear on minimum 1 ply jack post and be fastened to post with 18 gauge galvanized steel clips (ex. H2.5A), or continuous sheathing from king post to header or sill or equivalent.
- 3) **Window Sill Plate:** Sill plate shall be end nailed with three 10d nails each end through minimum 1 ply of king/jack posts, or continuous sheathing from king post to header or sill, or equivalent.
- 4) **King/Jack Posts:** Provide 20 gauge galvanized steel stud plate connector (ex. SP1) or equivalent from post to wall plate, top and bottom. Post plys shall be nailed together with 10d nails at 8 inches (204 mm) on center staggered full height.

R301.2.2.3.8.11 Brick Veneer

- 1) Exterior brick veneer shall not exceed 25 feet (7620 mm) in height above non-combustible foundation. Brick at gable peaks shall not exceed 40 feet (12,192 mm) in height above non-combustible foundation.
- 2) Exterior brick veneer shall comply with all other applicable Chapter 7 IRC requirements.
- 3) Interior brick veneer and masonry chimneys shall comply with Chapter 7 IRC requirements.

R301.2.2.3.8.12 Floor Openings

When floor openings in the second or third floors exceed 15 percent of the ground floor square footage, garage space excluded, they shall be considered as large floor openings.

- 1) The gross floor area shall be the area bounded by exterior walls.
- 2) Openings for stairs and egress are excluded from the net floor opening area.
- 3) Perimeter interior walls bounding a large floor opening shall be considered structural and shall be subject to all requirements as such. If perimeter walls are not present below opening perimeter (i.e. beam and column system is used), the supporting structure shall be engineered.

AMEND Section R312.1.1 as follows:

R312.1.1 Retaining Walls

Retaining walls 36" in height or greater are required to be designed by a licensed engineer and a plan submitted at the time of application for a permit. Height of the retaining wall shall be measured from the top of the footing to the top of the wall. A minimum of a 4 foot barrier (fence or guard) at the top of the wall may be required as determined by the Director of Code Enforcement.

AMEND Section R313.1 as follows:

EXCEPTION 1: Rename Exception to Exception 1.

EXCEPTION 2: An automatic residential fire sprinkler system is not required when there is a 2 hour wall between units.

DELETE R313.2 AND R313.2.1 in their entirety.

DELETE Section R401.3 and its Exception in their entirety and REPLACE as follows:

R401.3 Drainage and Foundation Elevation

Surface drainage shall be diverted to a storm sewer conveyance or other approved point of collection that does not create a hazard. Lots shall be graded to drain surface water away from foundation walls. The finish floor (elevation) shall be nominal 10 inches above the exterior finish grade (ground) and the finish grade shall slope a minimum of 8% (1 in 12) away from foundation for a minimum of 3 feet for drainage.

DELETE Section R403.1.1 “Minimum Size” in its entirety and REPLACE as follows:

R403.1.1 Minimum Size

Minimum size for concrete and masonry footings shall be as set forth in Table R403.1 and Figure R403.1(1). The footing width, W , shall be based on the load-bearing value of the soil in accordance with Table R401.4.1. All footings shall be at least 10 inches (255 mm) in thickness. Footing projections, P , shall be at least 2 inches (51 mm) and shall not exceed the thickness of the footing. The size of footing supporting piers and columns shall be based on the tributary load and allowable soil pressure in accordance with Table R401.4.1.

DELETE Section R403.1.4 “Minimum Depth” in its entirety and REPLACE as follows:

R403.1.4 Minimum Depth

All footings shall bear on undisturbed or properly compacted soils a minimum of 13 inches (330 mm) below grade. When applicable the depth of footing shall also conform to Section R403.1.4.1 through R403.1.4.2.

DELETE Sections N1101.1 through N1101.3 and REPLACE with the following:

N1101.1 Scope

This chapter sets forth the energy-efficiency related requirements for the design and construction of buildings regulated by this code.

Exception: Provided that they are separated by building envelope assemblies from the remainder of the building, portions of the building that do not enclose conditioned space shall be exempt from the building envelope provision, but shall comply with the provisions for building mechanical and service water heating systems.

N1101.2 Compliance for One and Two Family Dwellings

Compliance for one and two family dwellings shall be demonstrated by meeting the requirements of the 2015 Edition of the *ICC International Energy Conservation Code* for detached one and two family dwellings in Climate Zone 3A as found in Chapters 2, 3, 4, 5, and 6.

N1101.3 Compliance for Townhouses

Compliance for townhouses shall be demonstrated by meeting the requirements of the 2015 Edition of the *ICC International Energy Conservation Code* for residential buildings of Group R-2 or townhouses in Climate Zone 3A as found in Chapters 2, 3, 4, 5, and 6.

ADD Section E3405.8 as follows:

E3405.8 Weather Proof Panels

Weather Proof Panels are not allowed in the City of Bartlett per Ordinance #93-14.

AMEND Section E3406.2 as follows:

DELETE phrase [except as otherwise provided in the code]. This is a reference to allow other than copper conductors. Conductors of material other than copper may be used from a transformer through to the electrical panel box when proper connections are made.

ADD Section E3406.2(A) as follows:

E3406.2(A) Aluminum and copper-clad aluminum conductors are not allowed beyond the panel or in the interior of a residential house.

ADD TO Section E3601 as follows:

E3601.8 Unprotected Services Conductors Length

Service entrance conductors (without over current protection) shall not be extended more than 15 feet inside a building measuring horizontal from the point of entrance.

ADD TO Section E3702 as follows:

E3702.15 Any residential appliance or equipment rated at 1,000 watts and any electric motor of ½ H.P. (horse power) or larger shall be supplied by individual circuits of adequate capacity for the device to be connected. Receptacles installed in such circuits shall be single opening grounding type rated at 125% of the name plate current of the equipment to be connected, but in no case shall they be rated less than 20 amperes. Service outlets installed at heating equipment may be duplex outlets rated at 20 amperes.

ADD TO Section E3703 as follows:

E3703.3(A) Electric washer-dryer combinations rated 5 KW or less may be wired on a 30 ampere circuit with a 30 ampere grounding type receptacle. The service demand shall be 20 amperes.

ADD TO Section E3706 as follows:

E3706.1(A) Weather Proof Panels

Weather Proof Panels are not allowed in the City of Bartlett per Ordinance #93-14.

ADD TO Section E3901.4.2 as follows:

Exception: Receptacles are **NOT** required or allowed on moveable island counters without appliances (See Definitions below).

ADD to DEFINITIONS as follows:

MOVEABLE: Capable of being moved without being injured by one person or on wheels.

ADD Section E3910 as follows:

E3910 Fire Damage and Building Relocating

Buildings moved from one location to another that is to be used as a single family dwelling shall meet the following minimum requirements:

E3910.1 Service entrance conductors shall be governed by new service rules.

E3910.2 Kitchens shall have no less than two (2) circuits with a maximum of three (3) convenience outlets per circuit.

E3910.3 Lights and convenience outlets shall comply with existing branch circuit residential occupancies general requirements.

E3910.4 An inspection and written FIRE ruling must be obtained from the City of Bartlett Code Enforcement Office prior to commencing work on fire damaged jobs.

DELETE APPENDIX J IN ITS ENTIRETY AND REPLACE WITH THE FOLLOWING:

Appendix J-New Installations of Manufactured Homes

New manufactured homes are required to be provided with curtain wall masonry around the perimeter of the structure. The masonry curtain wall shall be a minimum of 4 inches wide and shall give an appearance of other buildings in the area of the installation. Trailer type hitches are to be removed from the structure prior to installation of the curtain wall.

